

H&V SERVICEPLAN

COMMISSIONING SHEET

PROJECT		CLIENT	
DATE		FLAT NO/ADDRESS	
BOILER TYPE (SYSTEM)			
CYLINDER TYPE			
APPLIANCE DETAILS			

LOCATION	TYPE	MAKE	MODEL (SERIAL NO)	FLUE TYPE

CHECK-LIST	TICK	COMMENTS
1) CHECK FLUE INSTALLATION. VISUAL INSPECTION FLUE TERMINATION. FLUE RESTRICTOR		
2) CHECK ELECTRICAL INSTALLATION - 240v SUPPLY SEPARATE L.V CONTROL WIRING. CHECK OPERATION OF ROOM STAT. CHECK OPERATION OF TIME CLOCK CHECK OPERATION OF PROGRAMMER HTG SWITCH/VALVE HWS SWITCH/VALVE & CYLINDER STAT		
3) GAS SUPPLY PRESSURE INPUT		
4) GAS BURNER PRESSURE - LOW POWER		CO2 LOW POWER
5) GAS BURNER PRESSURE - HIGH POWER		CO2 HIGH POWER
6) CO LOW POWER		CO HIGH POWER
7) SOFT LIGHT ADJUSTMENT (WHERE APPLICABLE)		
9) MAXIMUM POWER SETTING		
10) FLUSH LPHW SYSTEM - CLEAN/FLUSH/INHIBITOR CLEAN		
FLUSH		
INHIBITOR		